





PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.8685/25

Dated:23/06/2025

وادى الرب

It is certified that an inspection team headed by Mr. Muhammed Saleem, Quality Specialist (Name of Officers with designation) from Wadi Al Rayan Water Company (Government Approved: C.R:4030375249) inspected the Jeddah Ahdab International School, Jeddah, Saudi Arabia (Name & Address of the school) on 23/06/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. SB-8685/25 dated 23/06/25 of Wadi Al Rayan Water Company certified that the Jeddah Ahdab International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 2 years

Signature with Seal:

Name: Newannel

Designation:

Name & Address of the Office / Department:

To

The Manager

Jeddah Ahdab International School, Jeddah, Saudi Arabia.

(Name & Address of the Institution) Boys Section

منهج الهندي: ۲۲۷٤۳ CBSE No. 72743

> رقم الرخصة: ۲۹۰ امکا Abdah International Sch

Jeddah Ahdab International School

The Jan







		CERTIFICATE OF ANALYSIS		
			page 1 to 1	
Batch number: S8	S8-8685/25		Sample Details: Drinking water	
Production date	23/6/25		Expiry date	
Report status		Finish	Sample Source	Line machine
Sample temperature c		25 c	Sample Size	g G
		BOTTLED DRINKING WATER GSO STANDARD 1025/2014		1
AVERAGE CHEMICAL		RESULT	UNIT	
РН		7.1		6.5-8.5
CONDUCTIVITY		201	us/cm	<1000
T.D.S (asCaCO3)		108	ppm	100-500
T.H. (asCaCO3)		25	ppm	<200
T.A.C(asCaCO3)		21		
SILICA	SIOz	1		
		CATIONS		
CALCIUM	Ca	14		<75
MAGNESIUM	Mg	9		<30
SODIUM	Na	9		<100
MANGANESE	Mn	0.01		<0.4
POTASSIUM	IC .	0.01		
TOTAL IRON	Fe	0.01		<0.3
		ANIONS		
BICARBONATES	нсо з	23		
CHLORIDES	C1	27		<150
ULPHATES	SO 4	17		<150
NITRATES	NO 3	3		<50
ITRITES	NO 2	0.007		<3
AMMONIA	ин з	0		<0.5
LUORIDES	Fe	0.92		0.8 - 1.5
HOSPHATES	PO 4	0.51		
Microbiological test			CFU/100 ml	
otal Plate Count		25 تحدرات العالمة حدة		ISO 7899
oliform		Source Contract of Proceedings 22		
. coli		Boys Section 21		

ANVARSHAJA

Jeddah Ahdab International School